

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated:

It is certified that an inspection team headed by Dr. Dhananjay B. Kale(Name of Officers with designation) from PHC Usthal Dumal - Tal. Newasa(Name of Department/ Office) inspected the St. Joseph's Higher Sec. School(Name & Address of the school) on 24/12/2024 (date of inspection) and found that theSt. Joseph's Higher Sec. School (Name of school) has safe drinking water facilities for

the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the

school building &amp; the campus as per norms prescribed by the Central/ State/ U.T. Govt. The above is valid

for a period of 01 yearSignature with Seal: [Signature]Name: Dr. Dhananjay B. Kale

Medical Officer

Designation: P.H.C. Usthal Dumal  
Tal. Newasa, Dist. A. Naga

Name &amp; Address of the Office / Department:


[Signature]  
Principal

To

Principal

St. Joseph's Higher Secondary School  
Handinimgaon, Newasa,  
Ahmednagar, Maharashtra 414603.

St Joseph's Higher Secondary School  
Handinimgaon, Newasa, Ahmednagar,  
Maharashtra - 414 603

[Signature]  
Manager

St. Joseph's Higher Secondary School  
Handinimgaon, Newasa, Ahmednagar,  
Maharashtra - 414603

(Name &amp; Address of the Institution)

\* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

State / Regional / District / Public Health Laboratory AhmednagarE-mail-ID : dpheunr@gmail.comPhone No. : 02412354088

## REPORT ON CHEMICAL EXAMINATION OF WATER FOR DRINKING PURPOSES

Date of Collection :—

Date of Receipt :— 24.12.24Date of Examination :— 24.12.24

(All the Analytical Results are in mg./Litre except pH, Turbidity)

onward

Sr. No.	TEST PARAMETER	(1) Tap Water	(2)	(3)	BIS Specification 10500 : 2012 Normal Values	
					Desirable Limits	Permissible Limits
1.	Physical Appearance	Clear			—	—
2.	Odour	odourless			Agreeable	Agreeable
3.	Turbidity (as N.T.U.)	0.87			1.0	5.0
4.	pH Value	6.9			6.5 to 8.5	No relaxation
5.	Chlorides (as Cl)	39			250	1000
6.	Nitrates (as NO <sub>3</sub> )	1.01			45	No relaxation
7.	Total Hardness (as CaCO <sub>3</sub> )	54			200	600
8.	Alkalinity (as CaCO <sub>3</sub> )	62			200	600
9.	Total Dissolved Solids	180			500	2000
10.	Iron (as Fe)	0.01			0.3	No relaxation
11.	Fluoride (as F)	0.56			1.0	1.5
12.	Other Tests (if any)	—				
13.						
14.						
15.						
16.						
17.						
18.						
19.						
20.						

• This report is restricted only for the Sample/s Is Submitted to this Laboratory.

• This Sample/s Is / are not Collected by this Laboratory.

Manager

St. Joseph's Higher Secondary School  
Handinimgaon, Newasa, Ahmednagar,  
Maharashtra - 414603

Principal

St Joseph's Higher Secondary School  
Handinimgaon, Newasa, Ahmednagar,  
Maharashtra - 414603

[P.T.O.]



## REMARKS

A) Sample No. (s) \_\_\_\_\_ is/are potable / chemically fit for drinking purpose on the basis of analysed parameters only.

However, this / these water source/s can be used for drinking purpose only after proper treatment, disinfection and ascertaining it's bacteriological quality frequently or regularly.

B) Sample No. (s) \_\_\_\_\_ Contains \_\_\_\_\_

However, if there is no any other alternate source available nearby then this / these water Source/s can be used for drinking purpose only after proper treatment, disinfection and ascertaining it's bacteriological quality frequently or regularly.

C) Sample No. (s) \_\_\_\_\_ Contains \_\_\_\_\_

Hence, this / these water Source/s is / are chemically non-potable / unfit for drinking purpose on the basis of analysed parameters only.

## HEALTH SERVICES

No. 3

Date :- 11/1/25

Forwarded With Compliments To : सिंह मेडिकल हायर से. स्कूल  
हॉडि मिमगाव, ता-नेवासा

With reference to letter No. : \_\_\_\_\_ Dated :-

Fees Rs. : 940

Receipt No. and Date : 4461120

Shelke  
St. Joseph's Higher Secondary School  
Handinimgaon, Newasa, Ahmednagar,  
Maharashtra - 414 603

Shelke  
Manager  
St. Joseph's Higher Secondary School  
Handinimgaon, Newasa, Ahmednagar,  
Maharashtra - 414603

Shelke  
Junior Scientific Officer  
District Public Health Laboratory  
Ahmednagar